



DEPARTMENT OF THE NAVY
NAVAL FACILITIES ENGINEERING COMMAND MARIANAS
PSC 455, BOX 195 FPO AP 96540-2937

IN REPLY REFER TO:
4330
PRU22SC/SFH
31 MAY 2016

SUBJ: SOLICITATION NUMBER N40192-16-Q-7025, EMERGENCY GENERATORS FOR 36CES,
AAFB, GUAM

Amendment 0001- This is in regard to the solicitation notice posted to the Navy Electronic Commerce Online (NECO) Website on 24 May 2016 for solicitation no. N40192-16-Q-7025, EMERGENCY GENERATORS FOR 36CES, AAFB, GUAM

1. This Amendment 0001 is issued to accomplish the following (see Enclosure (1), Revised Specifications):
 - a. Provide answers to any requests for information as shown below. Both inquiries and answers therein are hereby incorporated as solicitation provisions.

No.	Date	Questions	Answers
1	5/26/16	Regarding items # 1.2, 1.3 in the specification sheet(Gasoline Generators) are these items specification measure in Peak Watts or Rated Watts. For Example, is item number 1.2 7kw Peak/Starting Watts or 7kw Rated Watts.	These items measure in Rated Watts.
2	5/26/16	Also in regards, to item #1.1 on the specification sheet the total dimensions listed mentioned are not to exceed 82" x 36". I have searched through various suppliers, CAT, Gillette, Bluestar, AKSA, Americas and the do not meet these dimension requirements. Do you have a particular brand that you received these generator restrictions from?	No, there is no particular brand. The restriction is based on the size of trailers that are already owned by the Government. However, the 60KW generator set dimensions are revised wherein the generator dimensions are not to exceed 100 inches in length and 50 inches in width (see Enclosure (1) Revised Specifications).
3	5/27/16	Please confirm "NEW" or "USED" types of generator units are required.	New generator units are required.

4	5/27/16	Request to extend bid deadline to June 3rd, 2016 – May 30th is a Federal Holiday (Memorial Day)	The quote due date is extended no later than 4:00 P.M. on Monday, 06 June 2016 (Guam Standard Date and Time).
5	5/27/16	Please confirm if bidder must provide Guam warranty service on the generators	Yes, the awarded Contractor must provide warranty service on Guam for the generators.
6	5/27/16	Request to extend delivery time line to 110 days from date of award	No. The current requirement for delivery of the generators no later than 80 calendar days from award is retained.
7	5/27/16	On Line Item 1.1, Please confirm size of day tank is 12 hour or 24 hour run time / Day tank is to be located as a sub-base fuel day tank?	The size of day tank should be 8 hours at full load. Yes, the day tank is to be located as a sub-base fuel day tank.
8	5/27/16	On Line Item 1.1, Please clarify if 60KW generator sets' enclosure requires sound attenuation or weather enclosure only	The 60 KW generators sets require both sound attenuation and weather enclosure.
9	5/27/16	On Line Item 1.1, Please advise if 12VDC battery system is acceptable for 60KW generator sets.	Yes, 12VDC battery system is acceptable for 60KW generator sets.
10	5/27/16	On Line Item 1.1, Please clarify if dual voltage capability for 60KW generator sets is by selector switch or manual reconfiguration of alternator windings	Dual voltage capability for 60KW generator sets is by selector switch.
11	5/27/16	On Line Item 1.1, Please clarify what is meant by rust proofing: Does this mean an aluminum corrosion resistant enclosure and rubberized anti-corrosion sub-base tank?	Yes. The definition of rust proofing is that the 60 KW generators will require an aluminum corrosion resistant enclosure and rubberized anti-corrosion sub-base tank.
12	5/27/16	On Line Item 1.1, Request to increase 60KW generator set dimensions not to exceed 100 inches in length and 50 inches in width	Yes, see answer to question number 2 above and Enclosure (1) Revised Specifications.



DEPARTMENT OF THE NAVY
NAVAL FACILITIES ENGINEERING COMMAND MARIANAS
PSC 455, BOX 195 FPO AP 96540-2937

- a. The quote due date is extended to no later than 4:00 P.M. on Monday, 06 June 2016 (Guam Standard Date and Time).
2. All other provisions and terms remain the same.
3. Quoters shall acknowledge all solicitation amendments (signature line provided below).

Sincerely,

A handwritten signature in black ink, appearing to read "Sheena Hess", is written over a horizontal line.

Sheena Hess
Contract Specialist

Contractor Acknowledgment:

Signature

Date

Name & Title